

COMPLIANCE DOCUMENT

Document No. RPE 2018-0419-00

HOLDER: ACTUATECH S.p.A.
Via San Lorenzo, 70 - 25069 – Villa Carcina (BS) - Italy

PRODUCT: Actuator

IDENTIFICATION: Model: GD 60 F5-F7

TESTED ACCORDING: EN 60529:1991 /A1:2000 A2/2013

TEST REPORT: RP 2018-0419-00 dated 2018-09-28

RESULTS: *This document attests that the Product here identified, has passed successfully the following tests in the order as listed in the test report mentioned above:*

- Verification of degree of protection IP6X
- Verification of degree of protection IPX8
- Verification of degree of protection IPX6

REMARKS: None

Date: 2018-09-28

ENV Sector Manager
Flavio Floriani

The present document describes in synthetic form only the test results achieved on the product identified and reported in the mentioned INTEK test report. This attestation does not involve the evaluation of the series production of products.

**PNEUMATIC ACTUATOR DOUBLE ACTING / SPRING RETURN TYPE
IP PROTECTION DEGREE**

DECLARATION

That the sealing system of Actuatech Double Acting and Spring Return pneumatic actuators are the same, therefore the results of protection degree IP6X – IPX8 – IP X6 of aluminium pneumatic actuator GD type, verified by INTEK Spa according to the Test report RP 2018-0419-00, can be extended to the same type in Carbon Steel and Stainless Steel.

G. Tanfoglio
Technical Department



S. Mazza
Quality Department



Villa Carcina, 05.10.2018

